



- NOTES**
1. TAPERED INSULATION SHALL SLOPE 1/4" PER FOOT. PROVIDE 2" MINIMUM THICKNESS AT ROOF DRAINS.
 2. THE ELEVATION OF OVERFLOW SCUPPERS (+29'-0") OR (+24'-9") IS THE BOTTOM OF THE HOLE IN THE WALL FOR THE SCUPPERS.
 3. ACOUSTICAL INSULATION REQUIRED AT ACOUSTICAL DECK - SEE STRUCTURAL.

**ADVANCED
TECHNOLOGY
CENTER -
DMACC**

ANKENY, IOWA

ROOF PLAN
1/8"=1'-0"
PLAN NORTH TRUE NORTH