



- NOTES**
1. TAPERED INSULATION SHALL SLOPE 1/4" PER FOOT. PROVIDE 2" MINIMUM THICKNESS AT ROOF DRAINS.
 2. THE ELEVATION OF OVERFLOW SCUPPERS (+28'-0") ON (+24'-9") IS THE BOTTOM OF THE HOLE IN THE WALL FOR THE SCUPPER.
 3. ACOUSTICAL INSULATION REQUIRED AT ACOUSTICAL DECK - SEE STRUCTURAL.

ROOF PLAN
 1/8"=1'-0"
 PLAN NORTH TRUE NORTH

ADVANCED TECHNOLOGY CENTER - DMACC
 ANKENY, IOWA